

## TABLE 1 – SUSPECT ACMS – SAMPLED

Site: 2029 Green, Detroit, MI 48209

Survey Date: 3/6/2014

Material Number & (Sample #)	Material Description	Material Location	F/NF <sup>1</sup>	Cond. <sup>2</sup>	% Asbestos & type <sup>3</sup>	EPA NESHAP Category <sup>4,5</sup>	OSHA Class Designation <sup>6</sup>	Estimated Quantity
2029-01A-C	12"x12" Wood Pattern Floor Tile	Dining And Living Rooms	NF	NA	NAD	NA	NA	NA
<b>2029-02A-E</b>	<b>Wall Plaster W/Skimcoat</b>	<b>Throughout</b>	<b>NF</b>	<b>NA</b>	<b>3% Chrysotile</b>	<b>NA</b>	<b>NA</b>	<b>4,500</b>
2029-03A-C	Wall Insulation	Throughout	F	NA	NAD	NA	NA	NA
2029-04A-C	Window Frame Sealant	Throughout	NF	NA	NAD	NA	NA	NA
2029-05A-C	Floor Sheeting	Beneath Dining Room and Kitchen Floors	NF	NA	NAD	NA	NA	NA
2029-06A-C	Drywall System	Throughout	NF	NA	NAD	NA	NA	NA
2029-07A-C	White RFP	Bathroom	NF	NA	NAD	NA	NA	NA
2029-08A-C	Weather Strip	Attic	NF	NA	NAD	NA	NA	NA
2029-09A-E	Plaster W/Textured Skim Coat	2 <sup>nd</sup> Floor	NF	NA	<1% Chrysotile	NA	NA	NA

1 **F** = Friable; **NF** = Non-friable

2 **Cond.** = Condition of Materials; Either good, fair or poor

3 **NAD** = No Asbestos Detected, **Ch** = Chrysotile, **Am** = Amosite, **PT** = Point Count Analysis

4 **NESHAP** Category - Regulated ACM (RACM), **Cat I NF**=Category I Non-Friable ACM, **Cat II NF**= Category II Non-Friable ACM

5 **NA** = Not Applicable

6 **OSHA/EPA Class Definitions:**

**Class I** asbestos work means activities involving the removal of TSI and surfacing ACM and PACM.

**Class II** asbestos work means activities involving the removal of ACM which is not thermal system insulation or surfacing material. This includes, but is not limited to, the removal of asbestos-containing wallboard, floor tile and sheeting, roofing and siding shingles, and construction mastics.

**Class III** asbestos work means repair and maintenance operations, where "ACM", including TSI and surfacing ACM and PACM, is likely to be disturbed.

**Class IV** asbestos work means maintenance and custodial activities during which employees contact but do not disturb ACM or PACM and activities to clean up dust, waste and debris resulting from Class I, II, and III activities.

**TABLE 1 – SUSPECT ACMS – SAMPLED**

Site: 2029 Green, Detroit, MI 48209

Survey Date: 3/6/2014

Material Number & (Sample #)	Material Description	Material Location	F/NF <sub>1</sub>	Cond. <sup>2</sup>	% Asbestos & type <sup>3</sup>	EPA NESHAP Category <sub>4,5</sub>	OSHA Class Designation <sup>6</sup>	Estimated Quantity
2029-10A-C	Light Heat Shield	1 <sup>st</sup> Floor Bedrooms	F	NA	NAD	RACM	Class I	NA
2029-11A-C	Transite Panel Debris	1 <sup>st</sup> Floor Back Bedroom	NF	NA	NAD	RACM	Class I	NA
2029-12A-C	Straight Pipe Insulation	Basement	F	NA	NAd	RACM	Class I	NA
<b>2029-13A-C</b>	<b>2"Pipe Wrap Insulation</b>	<b>Basement</b>	<b>F</b>	<b>NA</b>	<b>50% Chrysotile</b>	<b>RACM</b>	<b>Class I</b>	<b>40 LF</b>
<b>2029-14A-C</b>	<b>Pipe Joint Insulation</b>	<b>Basement</b>	<b>F</b>	<b>NA</b>	<b>70% Chrysotile</b>	<b>RACM</b>	<b>Class I</b>	<b>5 LF</b>
2029-15A-C	Chimney Liner	Basement	NF	NA	NAD	RACM	Class I	NA
2029-16A-C	Counterweight Rope	Throughout	F	NA	NAD	NA	NA	NA
2029-17A-C	Fabric Stair Tread	Basement Stairs	F	NA	NAD	NA	NA	NA

- 1 **F** = Friable; **NF** = Non-friable
- 2 **Cond.** = Condition of Materials; Either good, fair or poor
- 3 **NAD** = No Asbestos Detected, **Ch** = Chrysotile, **Am** = Amosite, **PT** = Point Count Analysis
- 4 **NESHAP** Category - Regulated ACM (RACM), **Cat I NF**=Category I Non-Friable ACM, **Cat II NF**= Category II Non-Friable ACM
- 5 **NA** = Not Applicable
- 6 **OSHA/EPA Class Definitions:**  
**Class I** asbestos work means activities involving the removal of TSI and surfacing ACM and PACM.  
**Class II** asbestos work means activities involving the removal of ACM which is not thermal system insulation or surfacing material. This includes, but is not limited to, the removal of asbestos-containing wallboard, floor tile and sheeting, roofing and siding shingles, and construction mastics.  
**Class III** asbestos work means repair and maintenance operations, where "ACM", including TSI and surfacing ACM and PACM, is likely to be disturbed.  
**Class IV** asbestos work means maintenance and custodial activities during which employees contact but do not disturb ACM or PACM and activities to clean up dust, waste and debris resulting from Class I, II, and III activities.